Office of the Municipal Councillors, Bhatpara

[Address: 1/1, West Ghoshpara Road, P.O. Kankinara, District: North 24 Parganas. PIN-743 126]

2581-2082, 2581-9515, 2581-9514. Fax: 2581-1318. Email: bhat_09@yahoo.com * bhatparamunicipality@gmail.com

No. I -4(F)/DR-2/.249.

Dated: 19:07.2023

Quotation in sealed cover are invited to a Electrification of Gaust House near Santineer in ward no-31 under Bhatpara Municipality under the following terms & conditions and will be received up to 12.00 noon. on or before 26.07.2023. The quotations will be opened on 26.07.2023 at 12.30 p.m.

TERMS & CONDITIONS

- 1. Bonafide and competent suppliers / dealers / sole authorized distributor having sound financial with technological status are eligible to submit Quotation.
- 2. Xerox copies of trade License, Income Tax, GST, Professional Tax, Certificates all self attested of their status should be submitted with this application.
- 3. No offer will be accepted if not signed duly by the proprietors / dealers or other authorized persons.
- 4. Specimen sample will be available for inspection at Electrical Dept. of Bhatpara Municipality at any working day between 11.00 A.M to 5.00 P.M.
- 5. No carriage cost will be provided for delivery of the articles at Bhatpara Municipality main store.
- 6. All the articles delivered are to be checked and verified by the authority concerned for final acceptance.
- 7. Rate should be inclusive of all charges i.e GST, etc. delivery cost at site.
- 8. The quantity as mentioned in the attached list may be increased / decreased, if required.
- 9. The undersigned shall have the right to accept / reject any or all quotation without assigning any reason.
- 10. Type of quotation Item wise
- 11. For details please visit Bhatpara Municipality office Notice Board.

Executive Officer Bhatpara Municipality

Copy forwarded to:-

- 1) Chairperson, Bhatpara Municipality.
- 3) The Executive Officer,
- 5) The Head Clark.
- 7) The Cashier,
- 9) The Assistant Engineer (Electrical),
- 2) Sri / Smt. Member, C-I-C
- 4) The Finance Officer,
- 6) The Accountant,
- 8) The Receiving Clerk,
- 10) The Store Keeper, Bhatpara Municipality

Executive Officer Bhatpara Municipality

Office of the Municipal Councillors, Bhatpara [Address: 1/1, West Ghoshpara Road, P.O. Kankinara, District: North 24 Parganas. PIN-743 126]

2581-2082, 2581-9515, 2581-9514. Fax: 2581-1318. Email: bhat_09@yahoo.com ★ bhatparamunicipality@gmail.com

No. I -4(F)/DR-2/249

Dated: 19:01:.2023

Enclosed Materials List

SI	Description Of Items	Unit	Qty
Ì	Supplying and fixing polythene pipe complete with fittings a necy. under ceiling/beam, bound with 22 SWG GI binding wire incl. supplying and drawing 1x18 SWG GI Wire as fish wire inside the pipes and fittings and providing 50 mm dia disc of MS sheet (20 SWG) having colour paint at one face fastened at the load point end of the polythene pipe with fish wire (synchronizing with roof/beam casting work of building construction,25mm dia 3mm thick Polythene Pipe. [PWD-17, Pg- E-2 (B-1-C)]	RM	80
2	Wiring in 1.1 KV grade single core stranded 'FR' PVC insulated & unsheathed copper wire (Brand approved by EIC) of following sizes in 25mm PVC casing-capping (Precision make) incl. necy. PVC clips, fittings etc. 2 x 36/0.3 (2.5 sqmm) + 1 x 22/0.3 (1.5 sqmm) [PWD-17, Pg-E-11 (D-1-C)]	RM	80
3	Distribution wiring in 2 x 22/0.3 (1.5 sqmm) single core stranded 'FR' PVC insulated & unsheathed copper wire in 20mm size PVC rigid conduit 'FR' (Precision make), with 1x22/0.3 (1.5 sqmm) single core stranded 'FR' PVC insulated & unsheathed copper wire for ECC, to light/fan/call bell points with Piano Key type switch fixed on MS CRC sheet metal (16 SWG) switch board cum JB on wall complete with 2 no. suitable size "Ph & N" copper bar with holes fixed on Bakelite / hard rubber insulation over the JB welded chairs incl. Bakelite / Perspex (wall matching color) top cover 3 mm thick and incl. 175mmx100mmx65mm inspection box, making earthing attachment, painting the MS box and mending good the damages to original finish. Average run 5 mtr. [PWD-2017, Pg-E-14 (E-2-a)]	Point	46
4	Supplying & fixing 240v. 4'-36/40 watt double Florescent tube light (FTL) fittings with complete all accessories (Cu. Choke, Starter etc.) and 2 nos. 4'-36/40 watt Tube (Phillips) fixing directly on wall.	No	12
5	Distn. wiring in 22/0.3 (1.5 sqmm) single core stranded 'FR' PVC insulated & unsheathed single core stranded copper wire (Brand approved by EIC) in 19 mm bore, 3 mm thick polythen pipe complete with all accessories embedded in wall to 240 V 6A 5 pin plug point incl. S&F 240 V 6A 3 pin Modular type plug socket & Modular type switch (Brand approved by EIC) incl. S&F earth continuity wire, fixed on 4 Module GI switch board with 3/4 Module top cover plate flushed in wall incl. mending good damages to original finish. 2x22/0.3 (Ph. & N) and 1x22/0.3 as ECC. [PWD-17, Pg- E-20 (G-3-v)]	Point	8
6	Supplying and fixing Sheet steel Main Switches on flat iron frame on wall, 100/125 A 415V TPN with fuse on L&N. [PWD-17, Pg-D-1 (1-b)]	No	1
7	Supplying & fixing 20 amps SP MCB [PWD-14, Pg-K-6]	No	3
8	Supplying & fixing MCB Enclosure 2way [PWD-17, Pg-K-1]	No	3
9	MCB Enclosure 4-way [PWD-17, Pg-K-1 SI-8]	No	3
10	Wiring in 1.1 KV grade single core stranded 'FR' PVC insulated & unsheathed copper wire (Brand approved by EIC) of following sizes in 25mm PVC casing-capping (Precision make) incl. necy. PVC clips, fittings etc. 2 x 56/0.3 (4 sqmm) + 1 x 22/0.3 (1.5 sqmm) [PWD-17, Pg-E-11, Sl-1-d]	RM	20
11	Supply & fitting fixing of A.C celling fan, 1200mm Sweep	No	10

Executive Officer Bhatpara Municipality